



CERTIFICATE
Of Conformity
EC Council Directive 89/336/EEC
as last amended by EC Directive 93/68/EEC
Electromagnetic Compatibility

Registration No.: ET0706191E-6

Applicant : Xiamen Kehua Hengsheng Co., Ltd.
International Trade Building, South Hubin Road, Xiamen,
Fujian, China.

Product : UPS

Identification : **Model No.** : FR-UK3320 (并机型)
Serial No. : N.A.
Rating : AC Input: 220/380V, 50Hz, 3×45A, 3Φ
DC Input: 348V
AC Output: 220/380V, 50Hz, 3×30.3A, 20kVA,
16kW, 3Φ

Standard : EN 50091-2: 1996

The certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex III of Council Directive 89/336/EEC, in its latest amended version, referred to EMC Directive. The certificate does not imply assessment of the production and does not permit the use of Lab's logo. The applicant of the certificate is authorized to use this certificate in connection with EC declaration of conformity to Article 10.1 of the Directive.



Jun. 16, 2007
Date

Certified by

David Zhang
David Zhang



The CE Marking may only be used if all relevant and effective EC Directives are complied with



DONGGUAN ESTEK SERVICES CO., LTD.

7F. 55 Tanglong East Road, Tangxia Town,
Dongguan City, Guangdong Province, P.R. China.

Tel: (86)769-82088138
Fax: (86) 769-82088139

